

DEPARTMENT OF WATER SUPPLY AND SANITATION

Chittoor, Chittoor District, Andhra Pradesh

WATER TEST REPORT


File No: 0112/2024

TR Date: 03/09/2024

1	Name of the Address of the customer	Secretary, Aarkay International School, Chittoor
2	Site Location	D. No:1-110, Coconut Street, Kattamanchi Rev-Village, Chittoor Mandal, Chittoor District, Andhra Pradesh, PIN:517 001
3	Sampling method	Supplied by customer (Secretary of the School)
4	Material Identification	RO Water
5	Date of Sample receipt	28/08/2024
6	Date of Sample testing	29/08/2024
7	Test done by	Sri. L.Umapathy
8	Method of test (IS code)	IS 3025 and 15185
9	Condition of sample when received	Good
10	Environmental condition a. Room temperature b. Relative humidity	27° Celsius 30%

Sl.No	Properties	Result	Desirable Limit
1	pH Value	6.25	6.5 – 8.5
2	Conductivity $\mu\text{s/cm}$	180	----
3	Turbidity, NTU	<1	1.0 Max
4	Total Dissolved Solids, mg/L	119	500 Max
5	Total Hardness as CaCo ₃ , mg/L	50	200 Max
6	Calcium as Ca, mg/L	7	75 Max
7	Magnesium as Mg, mg/L	6.0	30 Max
8	Alkalinity as CaCO ₃ , mg/L	50	200 Max
9	Chlorides as cl, mg/L	19.0	250 Max
10	Sulphates as SO ₄ , mg/L	3	200 Max
11	Nitrates as NO ₃ , mg/L	0.80	45 Max
12	Iron as NO ₃ , mg/L	0.01	1.0 Max
13	Fluoride as F, mg/L	0.1	1.0 Max
14	E. Coli/100 ml	Absent	Absent
15	Coliforms/100 ml	Absent	Absent

-----End of the report-----


Assistant Chemist
Water Supply & Sanitation
Chittoor(U),A.P
28/9/24